

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV020 Date of Visit: 10/31/23

Contractor Personnel on Site:

1. <u>Total Comfort</u>	4. _____
2. _____	5. _____
3. _____	6. _____

### Service Call Number

CSS# 88808 WO# 12035

### Description of Repairs

Labor and material to a.) install (2) Lochinvar FTX500 boilers with new boiler pumps b.) pipe the system to a true primary/secondary hydronic system for the new boilers design. c.) Provide the necessary piping, fittings and flue for the new boiler d.) insulate the new piping with fiberglass insulation e.) demo and properly dispose of the old boilers f.) drain and reuse the glycol from the hydronic loop g.) reconnect to the BAS system and reprogram for the new boilers

---

---

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Karlee Demain Date: 10/31/23

Signed: Karlee Demain

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Jennifer A Bailie Date: 10/31/2023

Signed: Jennifer A Bailie

E-Mail: jennifer.a.bailie.ctr@army.mil