

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY127 Date of Visit: 2/6/23

Contractor Personnel on Site:

1. <u>EMCOR</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 91359 WO# 20607

Description of Repairs

Noticed drive in local mode not remote and frequency set at 35 percent. Put to remote.
Found frequency bouncing around. From 10 percent to 50 percent Put back to local
Went to BMS computer could see static pressure reading going to 89,000 then to zero
then to .07. Located transducer found screen blank. Hoses were all connected.
Recommend to use Johnson Controls.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Karlee Demain Date: 2/16/23

Signed: Karlee Demain

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Mr. Lars Luffman/GS 09/ARA Date: _____

Signed: _____

E-Mail: _____ lars.luffman.civ@army.mil