

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY127 Date of Visit: 2/23/23

Contractor Personnel on Site:

1. <u>JCI</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 91359 WO# 21449

Description of Repairs

AHU-1 drive was tripping out because of power outage. The drive was in hand did not go in auto with loss of power. AHU1 controller is locked up, needs to be replaced or reset. Site did not want us to reset as they had some heat and did not want the unit completely disabled. Will submit separate quote for findings.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Karlee Demain Date: 3/8/23

Signed: Karlee Demain

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: _____ Date: _____

Signed: _____

E-Mail:

lars.luffman.civ@army.mil