

**CERTIFICATION OF WORK  
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY127 Date of Visit: 1/20/23

Contractor Personnel on Site:

1. <u>Atlas James Construction</u>	4. _____
2. <u>Roto Rooter</u>	5. _____
3. _____	6. _____

**Service Call Number**

CSS# 91407 WO# 20608

**Description of Repairs**

Ran a camera through both 4" lines, both lines have water issues. It seems the pipe itself has shifted underground and the joints where each section of pipe connects is letting ground water in. Also where both lines are having issues there is a stormwater catch basin that is clogged and not taking water to reroute it away from the building. When the water pools up where the catch basin is. It is forcing the water into the electrical conduit and emptying in your building and causing it to flood. Both conduit lines need to be re-paired roughly 150' of each line to stop the water from getting in, as well as the storm drain line needs to be jetted to be cleared out so the storm water flows freely. A follow up ticket will be needed for this repair.

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Karlee Demain Date: 1/20/23

Signed: Karlee Demain

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: \_\_\_\_\_ Date: \_\_\_\_\_

Signed: \_\_\_\_\_

E-Mail: \_\_\_\_\_