

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY065 Date of Visit: 3/30/23

Contractor Personnel on Site:

1. <u>Fox Fence</u>	4. _____
2. _____	5. _____
3. _____	6. _____

### Service Call Number

CSS# 91831 WO# 12072

### Description of Repairs

---

Repaired and serviced 2 sliding gates at US Army Reserve facility located at 2393 Colvin Boulevard including straightening of frame on MEP gate on south side of building, replacing 1 set trolleys adjusting with lubrication of rollers and guides on both gates

---

---

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Karlee Demain Date: 4/3/23

Signed: Karlee Demain

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Scott Kawasaki Date: 4/5/23

Signed: \_\_\_\_\_

E-Mail: scott.w.kawasaki.civ@army.mil