

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: USARC-Grafton WV014 Date of Visit: 8-17-23

Contractor Personnel on Site:

1. Sam Fisher
2. _____
3. _____
4. _____
5. _____
6. _____

Service Call Number

WO# 12306

Description of Repairs

Installed new seals and gaskets in backflow preventer. Tested backflow preventer.

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Sam Fisher Date: 8-17-23

Signed: Sanjeev

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: lahomma fowler Date: 8-17-23

Signed: 

E-Mail: lahomma.d.fowler.civ@army.mil