

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV046-02 Date of Visit: Feb 27, 2023

Contractor Personnel on Site:

1. <u>Ricky Barker</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 91885 WO# 1177

Description of Repairs

Verified exhaust fan in battery room works with the lights only. Replaced fan motor for exhaust hood in hazardous material room.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: Feb 27, 2023

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Tom McBurney/AFOS Date: Feb 27, 2023

Signed: 

E-Mail: thomas.m.mcburney.ctr@army.mil