

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV046-02 Date of Visit: Sep 15, 2023

Contractor Personnel on Site:

1. <u>Ricky Barker</u>	4. _____
2. _____	5. _____
3. _____	6. _____

**Service Call Number**

CSS# 91886 WO# 12107

### Description of Repairs

removed tape from photocell on outside light and it turned off. replaced all 6 t-5 bulbs in emergency bay light. replaced light in closet



## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: Sep 15, 2023

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Michael Dye / GS09 Date: Sep 15, 2023

Signed: 

E-Mail: michael.l.dye2.civ@army.mil