

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY051 Date of Visit: 2/05/23

Contractor Personnel on Site:

1. <u>Serve Pro</u>	4. _____
2. _____	5. _____
3. _____	6. _____

### Service Call Number

CSS# 92034 WO# 21073

### Description of Repairs

Emergency response where the following was performed a.) plugged the leak in the ceiling b.) returned heat to the building by turning the AHUs back on c.) set up and take down of equipment from Serve Pro d.) extracted water from carpet in offices 103, 104, & 105. e.) Cleaned and deodorized the carpet and apply a plant-based anti-microbial agent to more than the floor using a HEPA Vacuum. f.) cleaned tile in the entrance and foyer area. g.) set up (26) air dryers throughout the affected areas of the offices, main entrance and the foyer. h.) Set up dehumidifiers in the affected areas.  
Please Note this invoice is for Tidewater and Serve Pro's time and material to respond to the emergency, additional repairs will be submitted as part of another WO.

---

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Karlee Demain Date: 2/21/23

Signed: Karlee Demain

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Drinkwine, Justin M. GS-09 Date: 20230221

Signed: \_\_\_\_\_

E-Mail: justin.m.drinkwine.civ@army.mil