

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV046 Date of Visit: May 22, 2023

Contractor Personnel on Site:

1. <u>Ricky Barker</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 92210 WO# 12297

Description of Repairs

Found circulating pump locked up due to age . replaced pump and after wards main line filter plugged up and burst. after the water was turned off and heaters where allowed to dry out it was found the heater #3 had a bad control board and inducer motor. got new board and motor from navien and heater is back in operation



CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: May 22, 2023

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank:  Kyle Dean / SSG Date: May 22, 2023

Signed: 

E-Mail: kyle.d.dean3.mil@army.mil