

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV029-01 Date of Visit: Jun 15, 2023

Contractor Personnel on Site:

1. <u>Ricky Barker</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 92869 WO# 12557

Description of Repairs

Replaced broken Blemo actuator that
controls the hot water valve.



CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: Jun 15, 2023

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Adam Romesburg / GS09 Date: Jun 15, 2023

Signed: 

E-Mail: adam.c.romesburg.mil@army.mil