

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY070 Date of Visit: 6/14/23

Contractor Personnel on Site:

Greater Niagara

1. _____	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 93028 WO# 12568

Description of Repairs

Glycol has been filled in the system. Contacted chiller rep and they came out the next day and went thru and got them cleared (covered under warranty). Chiller is online and running
We did end up using all the glycol (55gals).

We are requesting a ticket for further replacement.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Karlee Demain Date: 6/19/23

Signed: Karlee Demain

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: John F. Granata Date: 06/20/2023

Signed: John F. Granata

E-Mail: john.f.granata.ctr@army.mil