

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV022 Date of Visit: May 26, 2023

Contractor Personnel on Site:


| | |
|------------------------|----------|
| 1. <u>Ricky Barker</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 93323 WO# 12796

Description of Repairs

in womens restroom i found the flush handle had a bad seal causing it to leak when flushed. replaced lever and tightened everything. got on the roof and found the exhaust fan was turned off, turned switch to on position and fan works as it should



CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: May 26, 2023

Signed: Richard A. Barker

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Travis Hufford Date: May 26, 2023

Signed: Travis Hufford

E-Mail: travis.a.hufford.civ@army.mil