

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY070 Date of Visit: 8/9/23

Contractor Personnel on Site:

1. <u>Stark Tech</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 93528 WO# 13004

Description of Repairs

C-Unit was shutdown on low coolant level alarm. Coolant was low in radiator. Topped off coolant and pressure checked system. No leaks found. Did find and tighten loose hose clamps.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Karlee Demain Date: 8/11/23

Signed: Karlee Demain

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: John F. Granata AFOS Date: 08/11/2023

Signed: John F. Granata

E-Mail: john.f.granata.ctr@army.mil