

## **CERTIFICATION OF WORK SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY051 Date of Visit: 6/12/23

#### Contractor Personnel on Site:

1. Johnson Controls	4. _____
2. _____	5. _____
3. _____	6. _____

## Service Call Number

93724

## Description of Repairs

We found multiple issues, one being the BMS for the building. This site does not have JCI controls, and we were unable to gain access. The other issues found were a faulty flow switch and circuit 1 was low on refrigerant meaning there is a leak. We recommend opening a new ticket for replacing the flow switch to at least keep the chiller operating. It also includes the removal of refrigerant to properly leak check circuit

## **CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Karlee Demain Date: 6/13/23

Signed:

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: **Noah Ingerson / AFOS** Date: **6/13/2023**

Signed: Noah Ingerson