

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV009 Date of Visit: Jun 20, 2023

Contractor Personnel on Site:

1. <u>Ricky Barker</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 94007 WO# 13363

Description of Repairs

Found floor drain where a/c and hot water tank both drain covered in dirt. removed outer layer from drain grate and then removed grate and broke dirt loose in drain. poured water down to flush and make sure it drains properly.



CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: Jun 20, 2023

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Jeremy Fowler / WS09 Date: Jun 20, 2023

Signed: 

E-Mail: jeremy.t.fowler.civ@army.mil