

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV029-01 Date of Visit: Aug 17, 2023

Contractor Personnel on Site:


1. <u>Ricky Barker</u>	4. _____
2. _____	5. _____
3. _____	6. _____

### Service Call Number

CSS# 94058 WO# 13374

### Description of Repairs

replaced bad exhaust motor and belt on one unit, reset one unit and the other two work when the bathrooms are triggered on.



## CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Richard A. Barker Date: Aug 17, 2023

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Adasm Romesburg / GS09 Date: Aug 17, 2023

Signed: 

E-Mail: adam.c.romesburg.mil@army.mil