

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY070 Date of Visit: 8/29/23

Contractor Personnel on Site:

- | | |
|-----------------------------|----------|
| 1. <u>Triton Mechanical</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 94237 WO# 13418

Description of Repairs

Powered down unit. Removed the old pcb board and condenser fan motor and replaced with new, powered up both the condenser and head unit and started to run, after 5 minutes the condenser shut down and error ch5 again, came up. Checked all wiring and was in the correct spots. Called tech support and went through the entire unit, checking board, motor, compressor, coils, and eev. Found the eev has bad readings and that is what took out the original board.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Karlee Demain Date: 8/29/23

Signed: Karlee Demain

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Scott Kawski

Print Name/Rank: _____ Date: _____

Signed: _____

E-Mail: _____