

## **CERTIFICATION OF WORK SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV029 Date of Visit: 7/18/23

#### Contractor Personnel on Site:

American Garage Door

1. \_\_\_\_\_
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_
6. \_\_\_\_\_

## Service Call Number

WO# 13416 WO# 13416

## Description of Repairs

Responded to emergency request found that the cables had come off when open and lost tension. Rest tension, reset limits, tightened operator chain, oiled and adjusted 12-2x8 16GA Wayne Dalton door.

## **CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Karlee Demain Date: 7/18/23

Signed: Karlee Demain

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Jennifer A Bailie/Contractor AFOS Date: 07/19/2023

Signed: Jennifer A Bailie

E-Mail: jennifer.a.bailie.ctr@army.mil