

## **CERTIFICATION OF WORK SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV029 Date of Visit: 8/11/23

#### Contractor Personnel on Site:

Ricky Barker

1. \_\_\_\_\_
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_
6. \_\_\_\_\_

## Service Call Number

WO# 13627

## Description of Repairs

Ricky investigated and was able to find that the airflow to the PTAC unit was blocked with luggage he moved the luggage to another location and the PTAC has been working.

## **CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Karlee Demain Date: 8/11/23

Signed: Karlee Demain

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Jennifer A Bailie Date: 8/11/2023

Signed: Jennifer A Bialis

E-Mail: [jennifer.a.bailie.ctr@army.mil](mailto:jennifer.a.bailie.ctr@army.mil)