

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY126 Date of Visit: 10/16/23

Contractor Personnel on Site:

- | | |
|--------------------------|----------|
| 1. <u>Tambe Electric</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 94420 WO# 13610

Description of Repairs

~~Respond to service call for troubleshooting/inspecting of service gear and panels that involve with lighting. Customers states the T5 fixtures in the Facility blow out prematurely. Looking for loose connections or some explanation that may cause power surges. Main MDP in electric has Surge Supressive monitors and has a Surge counter on it. It reads 53 surges since last reset 2-3 months ago. Opened gear and panels. Did find some loose breaker connections for Chiller and a couple other loose breaker connections. Not positive if this could cause surges but is possible. Checked and Tightened anything accessible in panels and gear opened up. Facilities is resetting the Surge Counter and will check in a month or so. Panels and gear all pass inspection and checked and tightened everything touched.~~

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Karlee Demail Date: 10/16/23

Signed: _____

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: John F. Granata AFOS Date: 10/16/2023

Signed: John F. Granata

E-Mail: john.f.granata.ctr@army.mil