

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV029 Date of Visit: Aug 10, 2023

Contractor Personnel on Site:

1. <u>Ricky Barker</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 94679 WO# 13651

Description of Repairs

found flow valve on urinal leaking through.
removed cap and found valve was missing.
replaced with new on from stock on my van
and returned water service to building.



CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: Aug 10, 2023

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Adam Romesburg / GS09 Date: Aug 10, 2023

Signed: 

E-Mail: adam.c.romesburg.mil@army.mil