

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV022 Date of Visit: 10/4/23

Contractor Personnel on Site:

1. _____	4. _____
2. _____	5. _____
3. _____	6. _____

### Service Call Number

CSS# 94685 WO# 13666

### Description of Repairs

Solving why exterior lights on the front of the building and two wall packs on the right side of the building were out. Diagnose the power for the main electrical panel to the lights and they have power to each light determined that the lights were bad. Checked with the person at the unit and they relayed that they could not tell me if all when out at once or over time.

Recommendation: To replace all four lights 2 wall packs and 2 parking lot lights.

---

---

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Karlee Demain Date: 10/9/23

Signed: Karlee Demain

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Jennifer A Bailie Date: 10/10/2023

Signed: Jennifer A Bailie

E-Mail: jennifer.a.bailie.ctr@army.mil