

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV010-01 Date of Visit: Aug 18, 2023

Contractor Personnel on Site:


| | |
|------------------------|----------|
| 1. <u>Ricky Barker</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 94690 WO# 13671

Description of Repairs

Found inducer motor not running during boiler inspections. After looking further into the problem i found the intake vent temp sensor was bad so i replaced it with one from boiler #3 . Boiler is working as it should



CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: Aug 18, 2023

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Christopher Letourneau / SSG Date: Aug 18, 2023

Signed: 

E-Mail: christopher.a.letourneau.mil@army.mil