

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FacID/Building: NY030 Date of Visit: 2/22/204

Contractor Personnel on Site:

1. <u>Steven Gay</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 95235 WO# 14090

Description of Repairs

Disassembled boiler number 1 and could find no sign of cracked heat exchanger.
Cotted controls engineer for hydrotherm and had to go through master controller and switch
controls to remote which are backwards in unit. Once in remote units went into standby and
master was firing boilers to maintain header set point.
Boilers are cycling off and on as needed and made repair parts list for boiler 1.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Julie Pape Date: 3/7/2024

Signed: Julie Pape

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: John F. Granata AFOS Date: 03/20/2024

Signed: John F. Granata

E-Mail: john.f.granata.ctr@army.mil