

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV010 Date of Visit: Nov 27, 2023

Contractor Personnel on Site:

1. <u>Ricky Barker</u>	4. _____
2. _____	5. _____
3. _____	6. _____

**Service Call Number**

CSS# 95302 WO# 14496

**Description of Repairs**

---

Found gasket had popped out of inducer chamber allowing raw gas to escape. repaired gasket and unit is operating as it should be. This problem was fixed just shortly after the inducer motor was swapped out.

---

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: Nov 27, 2023

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Lee Smith / Sgt Date: Nov 27, 2023

Signed: 

E-Mail: lee.m.smith63.mil@army.mil