

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY126 Date of Visit: 2/20/24

Contractor Personnel on Site:

1. <u>Johnson Controls</u>	4. _____
2. _____	5. _____
3. _____	6. _____

**Service Call Number**

CSS# 95322 WO# 14118

### Description of Repairs

Signal 15 and 17 short circuit upon arrival. Took signal 15 and 17 wires off and stray voltage present.  
~~Signal 15 showing 2 cpv and signal 17 showing 3VDC. Took all outside speaker/strobes down.~~  
~~Found 2 wheelock (BSA-804-84-5A) filled with bugs and coroded speakers emit static with only local speaker attached. Signal 15 and 17 still shorted after power cycle, need a replacement. FLEX 50 AMP and 2 new wheelock outdoor speakers and a new controller card. 2 troubles remain~~

---

---

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Karlee Demain Date: 2/22/24

Signed: Karlee Demain

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: John F. Granata AFOS Date: 02/23/2024

Signed: John F. Granata

E-Mail: john.f.granata.ctr@army.mil