

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY126 Date of Visit: 3/7/2024

Contractor Personnel on Site:

|                         |          |
|-------------------------|----------|
| 1. <u>Timothy Jones</u> | 4. _____ |
| 2. _____                | 5. _____ |
| 3. _____                | 6. _____ |

**Service Call Number**

CSS# 95726 WO# 14306

### **Description of Repairs**

Located boiler and performed inspection on boiler per manufacture spec. Changed flame rods and performed combustion.

Found boiler slightly out of range. Recommend cleaning flushing heat exchanger. Boiler control board will not stop cycling through parameters and cannot edit set points. Boiler is operating too warm and cannot currently be turned down internally. Called manufacture to get part numbers then called supply house to get a quote for parts. Also recommend replacing boiler relief valve as it is corroding from previous leaks. Cleaned up and checked out.

---

---

---

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Julie Pape Date: 3/14/24

Signed: Julie Pape

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: John F. Granata AFOS Date: 03/14/2024

Signed: John F. Granata

E-Mail: john.f.granata.ctr@army.mil