

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY070 Date of Visit: 3/5/2024

Contractor Personnel on Site:

1. <u>Timothy Jones</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 96208 WO# 14763

Description of Repairs

3/4/24 Checked in with John G. Located all 4 boilers in mechanical room. Boilers were already off on stanby due to temperatures outside being so warm. Started on boiler-2 and boiler-4 and pulled burners out to flush and brush heat exchangers, blow out the burners, replace igniters and flame sensors and return everthing back after thourough cleaning and inspection. Flushed drains-out and re hooked everything back up. Will continue tomorrow.

3/5/24 Returned back and checked in with John. Continued working on the other two boilers removing burners & washing heat exchanger using brush, vacuum and water. Relaxed all igniters and flame sensors. Tested boiler operation and boiler-2 closest to the front left is not firing off. Needs further troubleshooting. Recommend when it's colder out to fine tune using combustion analyzer. When operating boilers currently, was only able to run for a couple minutes due to being too warm and no call for heating. Cleaned up and checked out.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Julie Pape Date: 3/14/2024

Signed: Julie Pape

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: John E. Granata AFOS 03/14/2024

Signed: John F. Granata

E-Mail: john.f.granata.ctr@army.mil