

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV029 Date of Visit: Aug 26, 2024

Contractor Personnel on Site:

1. Ricky Barker
2. _____
3. _____
4. _____
5. _____
6. _____

Service Call Number

CSS# 96550 WO# 15228

Description of Repairs Replaced bad boiler circulating pump



CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: Aug 26, 2024

Signed: Richard A. Barker

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Jennifer Bailie / AFOS Date: Aug 26, 2024

Signed: Jennifer Bailie

E-Mail: jennifer.a.bailie.ctr@army.mil