

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV022 Date of Visit: May 30, 2024

Contractor Personnel on Site:


1. <u>Ricky Barker</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 96775 WO# 15187

Description of Repairs


Replaced faulty damper actuator only to find the room temp sensor and occupancy sensors are bad too



CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: May 30, 2024

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Jennifer Bailie / AFOS Date: May 30, 2024

Signed: 

E-Mail: jennifer.a.bailie.ctr@army.mil