

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV020-02 Date of Visit: May 8, 2024

Contractor Personnel on Site:

- | | |
|------------------------|----------|
| 1. <u>Ricky Barker</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 96931 WO# 15226

Description of Repairs

Found boiler No.5 with a broken motor to impeller coupler not allowing for the flow switch to make. Replaced coupler and retutned pump to service



CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: May 8, 2024

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Shane Yokum / GS/civ Date: May 8, 2024

Signed: 

E-Mail: shane.j.yokum.civ@army.mil