

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY126

Date of Visit: 08/05/2024

Contractor Personnel on Site:

- | | |
|-----------------------------|----------|
| 1. <u>Stephen Selenchik</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 98103

WO# 15825

Description of Repairs

- All 4 Hose Valve caps were installed on
the Hose Valves at the riser (see Pics).
- 2 gauges on the Riser were replaced by Davis Ulmer
on June 2024 (by someone else).

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Stephen Selenchik Date: 08/05/2024

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Neuat Chanthavisoek Date: 2024 08 05

Signed: 

E-Mail: Neuat.Chanthavisoek.Riv@army.mil

