

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY010 Date of Visit: 3-19-25 / 3-27-25

Contractor Personnel on Site:

1. Andrew Horn
2. _____
3. _____
4. _____
5. _____
6. _____

Service Call Number

FEMS# 2966410 WO# 17623

Description of Repairs

Rm 176 Repairs Blower motor, Wheel, Beary (3-17-25)
Rm 168, 143, 162, 7, Repairs dampen actuator motors
Rm -137 put New filter in place of missing one.
Rm 162- Repairs drain pipe are dampen actuator

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Andrew Horn Date: 3-27-25

Signed: Andrew Horn


To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Beth Sulzer GSA Date: 20250327

Signed: Beth Sulzer

E-Mail: _____



SERVICE WORK ORDER



GREATER NIAGARA

Mechanical, Inc.

7311 Ward Road ☺ North Tonawanda, NY 14120

Phone: 716.695.3600 ∞ Fax: 716.695.3700

DESCRIPTION OF WORK: Replace damper motor in Rooms 7, 168, 143, 162, LG mini splits. Rm 137, put in new filter instead of the missing filter. Rm 162 - Replace damper for damper actuator. Present is not as per quote.

After replacing all parts, perform Startup on all units and verify operation of parts replaced.

For Rm 162 - For water downstream from the ~~area~~ very noisy (162) likely
entirely dry with no leaves at the time.

At this time all press reports confirm the theory of the shell.

*SERVICE CHARGE
SUB TOTAL
TAX
TOTAL

COMPLETE
 INCOMPLETE

CUSTOMER SIGNATURE

*Service charge covers expense of truck, tools, and sundries.