

## **CERTIFICATION OF WORK SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY030 Date of Visit: 3/25/2025

#### Contractor Personnel on Site:

1. Postler & Jaeckle
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_
6. \_\_\_\_\_

## Service Call Number

WO# 17652

## Description of Repairs

Boiler valves were replaced. Relief valve on Navy side and water make up valve on Army side.

## **CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Postler & Jaekle Date: 3/25/2025

Signed: Dave Handee

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: John F. Granata AFOS Date: 05/21/2025

Signed: *John F. Granata*

E-Mail: john.f.granata.ctr@army.mil