

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY065 Tonawanda Date of Visit: 6/27/2025

Contractor Personnel on Site:

1. Andrew Horn
2. \_\_\_\_\_
3. \_\_\_\_\_

4. \_\_\_\_\_
5. \_\_\_\_\_
6. \_\_\_\_\_



Service Call Number

FEMS# 3156214 WO# 19156

### Description of Repairs

Replaced Valve on Chemical feed pot. Drained pot then removed top valve that was not opening and replaced with new valve. Then took apart. Sure it was opening and that water was flowing through.

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Andrew Horn Date: 6-27-25

Signed: Andrew Horn

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Troyon Y. Pate / MSG Date: 27 Jun 25

Signed: Troyon Y. Pate

E-Mail: troyony.pate.mil@army.mil