

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: Morgantown Date of Visit: 8-4-25

Contractor Personnel on Site:

1. Hunter Mouse
2. Mike Moore
3. _____
4. _____
5. _____
6. _____

Service Call Number

CSS# FEMS 3265615 WO# 107957

Description of Repairs

Damaged wiring in the motor pool fire panel was causing the ground fault. The issue was fixed and panel is normal.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Hunter Mouse Date: 8-4-25

Signed: Hunter Mouse

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Jennifer A Baillie / CTR Date: 8-4-25

Signed: Jennifer A Baillie

E-Mail: jennifer.a.baillie ctr@army.mil

