

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV022-02 Date of Visit: Mar 1, 2023

Contractor Personnel on Site:

- |                        |          |
|------------------------|----------|
| 1. <u>Ricky Barker</u> | 4. _____ |
| 2. _____               | 5. _____ |
| 3. _____               | 6. _____ |

### Service Call Number

CSS# 89903 WO# 11472

### Description of Repairs


Removed old busted ball valve from circulating pump line and replaced with a new one. Boilers are still unoperable due to bad backflow device.



## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: Mar 1, 2023

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Travis Hufford/GS9 Date: Mar 1, 2023

Signed: 

E-Mail: travis.a.hufford.civ@army.mil