

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV009-01 Date of Visit: 4/4/23

Contractor Personnel on Site:

1. <u>Ricky Barker</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 91594 WO# 12285

Description of Repairs

Somehow the exhaust fan got fastened to the roof curb so tightly it put the fan blade in a bind and wouldnt let it turn. got the fan an blade free and unit works as it should



CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: _____

Signed: Richard A. Barker

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Michaele Puliti / GS07 Date: 4/4/23

Signed: Michaele Puliti

E-Mail: michaele.c.puliti.civ@army.mil