

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV046-01 Date of Visit: Mar 22, 2023

Contractor Personnel on Site:

1. <u>Ricky Barker</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 91658 WO# 12032

Description of Repairs

Replace boiler control interface. Boiler tripped out and able to retrieve info of ignition failure. removed flame sense rod and cleaned. returned next day to no faults and both boilers working as they should.



CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: Mar 22, 2023

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Michael Dye / GS9 Date: Mar 22, 2023

Signed: 

E-Mail: michael.l.dye2.civ@army.mil