

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV029-01 Date of Visit: Mar 30, 2023

Contractor Personnel on Site:

1. <u>Ricky Barker</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 92461 WO# 12530

Description of Repairs

found toilet leaking at flush valve. tore apart
and found a ripped o ring. relaced o ring and
returned toilet to service.



CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: _____

Signed: Richard A. Barker

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Jessica Alvarez / SSGT Date: Mar 30, 2023

Signed: Jessica Alvarez

E-Mail: jessica.alvarez112.mil@army.mil