

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY067 BLDG1 Date of Visit: 7/11/23

Contractor Personnel on Site:

1. <u>Patrick Brown</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 94175 WO# 23331

Description of Repairs

Upon arriving at the site, I found the emergency boiler switch in the off position. I turned the switch back on
And the water temperature immediately started coming back up. I waited for to reach temperature and Checked several faucets and showers.
To ensure that was the only problem.

CERTIFICATION OF WORK


To be signed by the Contractor:

Print Name: Patrick Brown Date: 7/11/23

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Connery Zelk Date: 7/11/23
Signed: 

E-Mail: _____

