



Work Order
No: 60487

Armistead Mechanical Inc. Services
168 Hopper Avenue, Waldwick NJ 07463

Date: 8/19/2022
Status: Schedule

Service To: SSG Frederick J III Jr USARC Address: 2500 NY Route 17K Bullville NY 10915	Contact: Phone:
--	----------------------------------

Work Summary

Air Compressor at OMS will not maintain air pressure. Compressor will run but not engage at low pressure

Equipment

ID	Description	Type	Make	Model	Serial Number	Location	Year Installed

Labor

Date	Technician	Hours
8/19/2022	20078 (William G. Rimm)	2.00

Parts

Description	Quantity

Notes

Topic	Note
WORK ORDER NOTES	8/19/22 BR look at and quote repairs to air compressor found motor trying to run but not starting and tripping starter over load traced out found motor was single phasing do to a bad wire connection repaired connection started and tested unit operating fine

Customer Signature		Signed By		Date	
--------------------	--	-----------	--	------	--