

Wednesday, November 4, 2020 9:58 AM EST

**CMI Management**  
**MD 021**  
**1850 Baltimore Rd**  
**Rockville MD 20851-1298**  
**(202) 437-5119**

Report Number: **343331**  
 Recorded By: **Paul Giammanco**  
**(301) 721-2663**  
**pgiammanco@bondwater.com**

On-Site Time: **9:30 AM EST to 10:15 AM EST**

## 1850 Baltimore Rd - Closed Loop

| Test                                          | Closed loop       | City Water     |  |  |
|-----------------------------------------------|-------------------|----------------|--|--|
| Conductivity (as mmhos)                       | 3800<br>Record    | 430<br>500 max |  |  |
| Molybdate (ppm as Mo)                         | 100<br>65 - 150   |                |  |  |
| pH                                            | 8.5<br>8.5 - 10.5 | 7.8<br>7 - 8   |  |  |
| Alkalinity, total (ppm as CaCO <sub>3</sub> ) |                   | 80<br>180 max  |  |  |
| Chlorides                                     |                   | 40<br>50 max   |  |  |
| Hardness, total (ppm as CaCO <sub>3</sub> )   |                   | 120<br>200 max |  |  |

### Opening Comment

Performed service visit.

### Closed loop

Online 

Performed all tests for closed glycol system. All readings were within desired range, providing optimal corrosion protection.