

Wednesday, February 10, 2021 9:22 AM EST

CMI Management
 MD 021
 1850 Baltimore Rd
 Rockville MD 20851-1298
 (202) 437-5119

Report Number: 359321
 Recorded By: Paul Giammanco
 (301) 721-2663
 pgiammanco@bondwater.com
 On-Site Time: 9:00 AM EST to 9:45 AM EST

1850 Baltimore Rd - Closed Loop

Test	Closed loop	City Water		
Conductivity (as mmhos)	4400 Record	710 Record		
Molybdate (ppm as Mo)	125 65 - 150			
pH	8.5 8.5 - 10.5	7.8 7 - 8		
Alkalinity, total (ppm as CaCO ₃)		70 180 max		
Chlorides		120 Record		
Hardness, total (ppm as CaCO ₃)		140 200 max		

Opening Comment

Performed service visit.

Closed loop

Online 

Performed all tests for closed glycol system
 All readings were within desired range, providing optimal corrosion protection.