

Thursday, February 13, 2020 3:40 PM EST

CMI Management  
 MD 021  
 1850 Baltimore Rd  
 Rockville MD 20851-1298  
 (202) 437-5119

Report Number: 289793  
 Recorded By: Paul Giammanco  
 (301) 721-2663  
 pgiammanco@bondwater.com  
 On-Site Time: 1:45 PM EST to 2:15 PM EST

## 1850 Baltimore Rd - Closed Loop

Test	Closed loop	City Water		
Conductivity (as mmhos)	3500 3500 max	360 500 max		
Molybdate (ppm as Mo)	30 65 - 150			
pH	8.3 8.5 - 10.5	7.8 7 - 8		
Alkalinity, total (ppm as CaCO <sub>3</sub> )		110 180 max		
Chlorides		40 50 max		
Hardness, total (ppm as CaCO <sub>3</sub> )		70 200 max		

### Opening Comment

Performed monthly service visit.

**Closed loop**

Online 

Performed all tests for hot loop. Molybdate levels were low, so I hand pumped a gallon of 5011 into system to bring levels back into range. I also left the steel filter cartridge along with a box a corresponding filters in the mechanical room.