

Friday, February 26, 2021 10:30 AM EST

Tidewater, INC
 MD-002
 700 E. Ordnance Rd
 Baltimore MD 21226
 (410) 540-8700

Report Number: 360354
 Recorded By: Paul Giammanco
 (301) 721-2663
 pgiammanco@bondwater.com
 On-Site Time: 10:00 AM EST to 10:30 AM EST

MD-002 - CLOSED LOOPS

Test	Chill Water Glycol Loop	Hot Water Loop		
Conductivity (as mmhos)	5000 5000 max	5000 Record		
pH	10.0 8.5 - 10	10.0 8 - 10		
Molybdate (ppm as Mo)	130 50 min	250 50 min		

Opening Comment

Performed service visit.

Chill Water Glycol Loop

Online 

Performed all tests for chilled glycol loop. All readings were within desired range, providing optimal corrosion protection.

Hot Water Loop

Online 

Performed all tests for hot water loop. All readings were within desired range, providing optimal corrosion protection. Upon taking my sample, I noticed the water is very dirty. I spoke with John Brown about this, and I've been informed that the filter housings are still not installed. I recommend getting them installed asap to clean the dirt out before it poses an issue for the system.