

Thursday, May 6, 2021 10:58 AM EDT

**CMI Management**  
**MD 021**  
**1850 Baltimore Rd**  
**Rockville MD 20851-1298**  
**(202) 437-5119**

Report Number: **364659**

Recorded By: **Paul Giammanco**  
**(301) 721-2663**  
**pgiammanco@bondwater.com**

On-Site Time: **10:30 AM EDT to 11:00 AM EDT**

## 1850 Baltimore Rd - Closed Loop

Test	Closed loop	City Water		
Conductivity (as mmhos)	3500 Record	350 Record		
Molybdate (ppm as Mo)	150 65 - 150			
pH	8.5 8.5 - 10.5	7.8 7 - 8		
Alkalinity, total (ppm as CaCO <sub>3</sub> )		60 180 max		
Chlorides		60 Record		
Hardness, total (ppm as CaCO <sub>3</sub> )		100 200 max		

### Opening Comment

Performed service visit.

#### Closed loop

Online 

Performed all tests for closed loop. All readings were within desired range, providing optimal corrosion protection.

Bond Water Technologies, Inc. recommends that you perform regular and/or daily analysis to control chemical levels and cycles of concentration within established limits. Test results reflect conditions during the point in time when the analysis was performed. Additional testing may be performed upon request. As operating conditions vary, test results will change over time. Notwithstanding anything to the contrary contained in the Agreement or otherwise, (i) Bond Water Technologies and its insurers are not liable for losses caused by the Customer's wrongful acts or omissions, (ii) Bond's program does not cover and it makes no guarantees with respect to waterborne pathogens including Legionella or against health risks therefrom, and (iii) in no event shall either party be liable for any consequential or indirect damages.