

Tuesday, August 4, 2020 2:56 PM EDT

CMI Management
 MD 021
 1850 Baltimore Rd
 Rockville MD 20851-1298
 (202) 437-5119

Report Number: 328774
 Recorded By: Paul Giammanco
 (301) 721-2663
 pgiammanco@bondwater.com
 On-Site Time: 8:30 AM EDT to 9:00 AM EDT

1850 Baltimore Rd - Closed Loop

Test	Closed loop	City Water		
Conductivity (as mmhos)	2100 3500 max	390 500 max		
Molybdate (ppm as Mo)	100 65 - 150			
pH	8.6 8.5 - 10.5	7.8 7 - 8		
Alkalinity, total (ppm as CaCO ₃)		90 180 max		
Chlorides		50 50 max		
Hardness, total (ppm as CaCO ₃)		130 200 max		

Opening Comment

Performed quarterly service visit.

Closed loop

Online 

Performed all tests for closed loop system. All readings were within desired range, providing optimal corrosion protection.