



Proudly serving the entire states of Virginia & North Carolina.

Altavista, VA • Charlottesville, VA • Chesapeake, VA • Manassas, VA
Lynchburg, VA • Richmond, VA • Raleigh, NC • Charlotte, NC

P.O. Box 119 • Altavista, VA • 800.789.7199 • service@mooreselectric.com

Billing Address	Site Address
Customer: TIDEWATER, INC Address: 6625 SELNICK DRIVE Phone: 614-623-9569	Customer: USARC VA701 SUFFOLK Address: 886 CAROLINA ROAD Phone: 614-623-9569
Service Call #: COM0172710	Call Type: COM-PLMB

Service Requested

PO: 16350 NTE: \$350 ETA: BY END OF FEB SEV: HIGH

It is time for the annual backflow inspections We would like to schedule starting February 8th. Please ask your plumber to update Manufacturer/ Model Number/Serial Number while onsite.

PMA-3Y027 3Y026 Wilkins 1 in
PMA-3Y027 3Y027 Watts 3 in
PMA-3Y027 3Y028 Watts 3 in

Problems

Description	Tech	Equip. Desc and Model	Manufacturer	Equip. Serial	Asset ID
BACKFLOW TEST	MATTFRASER	PI	PLUMBING OR ELECTRICAL EQUIPMENT		

Tech Notes

Tech: MATTHEW FRASER, Date: 2/3/22 2:54 PM - Mechanical room 130 1 inch Wilkins Zurn RPZ 10 Feet in the ceiling.

Mechanical room 110 3 inch watts domestic water RPZ and a three-quarter wrench watch RPZ straight ahead through the door.

All three backflow devices passed inspection.

Labor

Date	Technician	Description	Hours
2/3/2022	MATTHEW FRASER	COMMERCIAL TRAVEL TIME	2.00
2/3/2022	MATTHEW FRASER	REGULAR PLUMBING LABOR	2.25

Materials

Date	Part Number	Description	Quantity
No records found			

Signed By	Matt Fraser	Signature		Date	2/3/2022
-----------	-------------	-----------	--	------	----------